

 Campbell STRUCTURAL Robert L. Campbell Structural Engineer, P.C. 200 E. 16TH Street, Suite 100 Yuma, AZ 85364	JOB No.: 25032	DATE: 04/23/25	DESIGNED BY: RLC CHECKED BY: RLC	SHEET 1 OF 33
CLIENT: Sternco Engineers, Inc. 202 S. 1 st Ave, Suite 205 Yuma, AZ 85364 PROJECT: Yuma County Foothills Library HVAC Replacement – Structural Report 13226 E. South Frontage Rd, Yuma AZ 85367				

STRUCTURAL CALCULATIONS

DESIGN DATA

CALCULATION SUMMARY


This project consists of replacing the existing roof top HVAC units at the Yuma Co. Foothills Library with new heavier units. The original construction documents show the steel roof joist are scheduled to support 1,500 lb mechanical units. The replacement units are in the range of 1,800 lb.

RCSE performed structural calculations to determine the existing joist shear and moment capacity. The same joists were checked with an actual dead load based on our field observations along with the 1,800 lb mechanical unit weight.

The results of our analysis indicate the existing steel joist capacity exceeds the new demand on the joist. All shear and moment demand/capacity ratio checks are less than 1.0 and consequently, no joist strengthening is required.

CODE DATA


Building Code: 2018 I.B.C.



STEEL JOIST ORIGINAL DESIGN CAPACITY


SJ1 DL+LLR LLR
 $w = 255 \text{ PLF} / 135 \text{ PLF}$

$P = 1500 (\frac{1}{4}) = 375 \#$




SJ2

$w = 255 \text{ PLF} / 135 \text{ PLF}$
 $P = 375 \#$




SJ3

$w = 255 / 135 \text{ PLF}$
 $P = 375 \#$




SJ4

$w = 255 / 135 \text{ PLF}$
 $P = 375 \#$



SJ5


$w = 255 / 135 \text{ PLF}$
 $P = 375 \#$



NEW MECH UNITS STEEL JOIST PROPOSED DESIGN DEMAND


SJ1 DL+LLR LLR
 $w = 233 \text{ PLF} / 135 \text{ PLF}$

$P = 1800 (\frac{1}{4}) = 450 \#$




SJ2

$w = 233 \text{ PLF} / 135 \text{ PLF}$
 $P = 450 \#$




SJ3

$w = 233 / 135 \text{ PLF}$
 $P = 450 \#$




SJ4

$w = 233 / 135 \text{ PLF}$
 $P = 450 \#$



SJ5

$w = 233 / 135 \text{ PLF}$
 $P = 450 \#$



EXISTING VS. NEW UNITS WEIGHTS

MARK	EXISTING UNIT INFORMATION			EXISTING UNIT WEIGHT W/ ACCESSORIES (LBS)	NEW UNIT WEIGHT W/ ACCESSORIES (LBS)				REMARKS
	MAKE	MODEL	SERIAL #		UNIT ONLY	PE ACCESSORY	CURB ADAPTER	TOTAL	
HP-1, 2	TRANE	WSC120A3R0A	620102570L (HP-1, TYP)	941 + 344 = 1285	1266	160	115	1561	1,2
HP-3,4,5,6,7	TRANE	WSC120A3R0A	620102586L (HP-3, TYP)	941 + 344 = 1285	1306	160	115	1581	1,2
REMARKS:									
1.	EXISTING UNITS INCLUDE CANFAB MODEL 6144-MPE ECONOMIZER AND POWERED EXHAUST ACCESSORIES.								
2.	ALL (7) UNITS SCHEDULED ARE THE SAME MODEL NUMBER AND A TYPICAL SERIAL NUMBER IS SHOWN.								

NEW UNIT DESIGN WT
 $1581 + 215 = 1,800\#$

ORIGINAL DESIGN WT.
 curb
 $1285 + 215 = 1,500\#$

Robert L. Campbell
Structural Engineer, P.C.
183 E. 24th Street, Suite 7
Yuma, AZ 85364

PROJECT

Yuma County Library District
Foothills Branch Library
Yuma, AZ

Page 6 of 33 SHEET NO.:

07040

3

DATE:

Jun-07

BY:

KLB

GRAVITY DESIGN LOADS

2003 INTERNATIONAL BUILDING CODE - Dead and Live Loads

ROOF - High Roof Structure

DEAD LOADS

Corrugated Metal Roofing	2.0 psf
6" Polystyrene	3.0 psf
Steel Accoustic Deck	4.4 psf
Steel Beams	2.0 psf
MPE	2.0 psf
Sprinkler	1.5 psf
Misc.	1.1 psf
Total DL	16.0 psf

LIVE LOADS

Roof L_r **20 psf** (reducible)

BUILT UP ROOF - Main Structure

DEAD LOADS

Roofing	2.5 psf
6" Polystyrene	1.0 → 3.0 psf
Steel deck	2.3 psf
Steel Joists	2.0 psf
5/8 Gypboard Ceiling	1.8 → 2.8 psf
MPE	1.8 psf
Sprinkler	1.5 psf
Misc.	2.1 psf
Total DL	18.0 psf

ACOUSTIC CLG.

ACTUAL
DL = 15 PSF

LIVE LOADS

Roof L_r **20 psf** (reducible)

CEILING - Vestibule Framing

DEAD LOADS

Light Gauge Framing	2.0 psf
Plywood	1.5 psf
5/8 Gypboard Ceiling	2.8 psf
MPE	1.8 psf
Sprinkler	1.9 psf
	10.0 psf

LIVE LOADS

Roof L_r (reducible)

Robert L. Campbell
Structural Engineer, P.C.

PROJECT

Foothills Branch Lib.

JOB NO.

07040

DATE

BY

SHEET NO.

Joist Design / Criteria

$$DL = 18 \text{ psf}$$

$$LLR = 20 \text{ psf}$$

$$W = 6.67(18 + 20) \text{ psf} = (120 + 133) \text{ plf}$$

Used: 16k (255/135) at 23'-2" span

ORIGINAL
CAPACITY →

20k (255/135) at 28'-1" span

24k (255/135) at 33'-4" span

26k (255/135) at 40'-2" span

ACTUAL UNIFORM

$$\begin{matrix} (233/135) \\ \uparrow \quad \uparrow \\ TL \quad LLR \end{matrix}$$



INNOVATIONS FOR LIVING®

FOAMULAR® Extruded Polystyrene (XPS) Insulation

SI and I-P Units for Selected Properties

Technical Bulletin

This bulletin provides thermal conductivity, thermal resistance, density and compressive strength for FOAMULAR® 150, 250, 400, 600 and 1000 insulation in thicknesses of 2", 3" and 4". SI units are provided in the tables, followed by I-P units in parenthesis.

FOAMULAR® 150 Insulation

Thickness, mm	Thermal Conductivity, W/mK, max.	Thermal Resistance, m²K/W, min.	Density, kg/m³, min.	Compressive Strength, kPa, min.
100 (4")	0.029 (k=0.20)	3.53 (R-20)	20.8 (1.3 pcf)	103 (15 psi)
75 (3")	0.029 (k=0.20)	2.65 (R-15)	20.8 (1.3 pcf)	103 (15 psi)
50 (2")	0.029 (k=0.20)	1.77 (R-10)	20.8 (1.3 pcf)	103 (15 psi)

FOAMULAR® 250 Insulation

Thickness, mm	Thermal Conductivity, W/mK, max.	Thermal Resistance, m²K/W, min.	Density, kg/m³, min.	Compressive Strength, kPa, min.
100 (4")	0.029 (k=0.20)	3.53 (R-20)	24.8 (1.55 pcf)	172 (25 psi)
75 (3")	0.029 (k=0.20)	2.65 (R-15)	24.8 (1.55 pcf)	172 (25 psi)
50 (2")	0.029 (k=0.20)	1.77 (R-10)	24.8 (1.55 pcf)	172 (25 psi)

FOAMULAR® 400 Insulation

Thickness, mm	Thermal Conductivity, W/mK, max.	Thermal Resistance, m²K/W, min.	Density, kg/m³, min.	Compressive Strength, kPa, min.
100 (4")	0.029 (k=0.20)	3.53 (R-20)	28.9 (1.8 pcf)	276 (40 psi)
75 (3")	0.029 (k=0.20)	2.65 (R-15)	28.9 (1.8 pcf)	276 (40 psi)
50 (2")	0.029 (k=0.20)	1.77 (R-10)	28.9 (1.8 pcf)	276 (40 psi)

FOAMULAR® 600 Insulation

Thickness, mm	Thermal Conductivity, W/mK, max.	Thermal Resistance, m²K/W, min.	Density, kg/m³, min.	Compressive Strength, kPa, min.
100 (4")	0.029 (k=0.20)	3.53 (R-20)	35.3 (2.2 pcf)	414 (60 psi)
75 (3")	0.029 (k=0.20)	2.65 (R-15)	35.3 (2.2 pcf)	414 (60 psi)
50 (2")	0.029 (k=0.20)	1.77 (R-10)	35.3 (2.2 pcf)	414 (60 psi)

FOAMULAR® 1000 Insulation

Thickness, mm	Thermal Conductivity, W/mK, max.	Thermal Resistance, m²K/W, min.	Density, kg/m³, min.	Compressive Strength, kPa, min.
100 (4")	0.029 (k=0.20)	3.53 (R-20)	48.1 (3.0 pcf)	690 (100 psi)
75 (3")	0.029 (k=0.20)	2.65 (R-15)	48.1 (3.0 pcf)	690 (100 psi)
50 (2")	0.029 (k=0.20)	1.77 (R-10)	48.1 (3.0 pcf)	690 (100 psi)

Notes:

- SI, the International System of Units (Metric). I-P, inch-pound units (English).
- Conversions are approximate, rounded to the nearest significant digit that is customary for a given property as shown in the tables.
- I-P unit definitions:
Thermal Conductivity, "k" = Btu·in/ft²·hr·°F
Thermal Resistance, "R" = hr·ft²·°F/Btu
Compressive Strength, "psi" = pounds per square inch
Density, "pcf" = pounds per cubic foot

$$\frac{3}{12} \times 4 = 1.0 \text{ PSF}$$

Disclaimer of Liability

Technical information contained herein is furnished without charge or obligation and is given and accepted at recipient's sole risk. Because conditions of use may vary and are beyond our control, Owens Corning makes no representation about, and is not responsible or liable for the accuracy or reliability of data associated with particular uses of any product described herein. Nothing contained in this bulletin shall be considered a recommendation.



INNOVATIONS FOR LIVING®

OWENS CORNING FOAM INSULATION, LLC
ONE OWENS CORNING PARKWAY
TOLEDO, OHIO 43659

1-800-GET-PINK®
www.owenscorning.com

Pub. No. 10015703. Printed in U.S.A. September 2011. THE PINK PANTHER™ & ©1964-2011 Metro-Goldwyn-Mayer Studios Inc. All Rights Reserved. The color PINK is a registered trademark of Owens Corning. ©2011 Owens Corning.





Campbell
STRUCTURAL

200 E. 16th St., Suite 100
Yuma, AZ 85364
(928) 726-2646

JOB 25032 Yuma Co. Food/4:11:15 Library

SHEET NO. _____

Page 9 of 33
OF

CALCULATED BY RLC

DATE 4/20/25

CHECKED BY _____

DATE _____











SCALE _____

DEMAND/CAPACITY TABLE

REF: RISA 3d Printout

	CAPACITY		DEMAND		DCR	
	V (K)	M (K)	(K) V	(K) M	V	M
SJ1	4.135	27.6	3.94	26.05	0.95	0.94
SJ2	3.889	25.78	3.645	23.78	0.94	0.92
SJ3	3.961	29.46	3.73	28.2	0.94	0.96
SJ4	4.03	29.18	3.82	27.92	0.95	0.96
SJ5	4.157	27.3	3.97	25.65	0.96	0.94


DEMAND ON JOIST IS LESS THAN CAPACITY
THEREFORE JOIST ARE O.K.



RCSE
Rob
25032

Steel Joist Capacity Check

SK-1
Steel Joist Check.r3d



Loads: BLC 1, Dead




RCSE
Rob
25032

Steel Joist Capacity Check

SK-2

Steel Joist Check.r3d



Loads: BLC 2, Roof Live



RCSE


Rob

25032

Steel Joist Capacity Check

SK-3

Steel Joist Check.r3d



Loads: LC 2, DL+RLL




RCSE
Rob
25032

Steel Joist Capacity Check

SK-4

Steel Joist Check.r3d


Member S.J1 Capacity, Envelope



Selected Location Values:

Location: 0 ft
Max Value: 3.755 (LC 2) k
Min Value: 3.755 (LC 2) k


Member SJ1 Capacity, Envelope



Selected Location Values:

Location: 0 ft
Max Value: 0 (LC 2) k-ft
Min Value: 0 (LC 2) k-ft


Member SJ2 Capacity, Envelope



Selected Location Values:

Location: 0 ft
Max Value: 3.889 (LC 2) k
Min Value: 3.889 (LC 2) k


Member SJ2 Capacity, Envelope



Selected Location Values:

Location: 0 ft
Max Value: 0 (LC 2) k-ft
Min Value: 0 (LC 2) k-ft


Member SJ3 Capacity, Envelope



Selected Location Values:

Location: 0 ft
Max Value: 3.961 (LC 2) k
Min Value: 3.961 (LC 2) k

Member SJ3 Capacity, Envelope




Selected Location Values:

Location: 0 ft

Max Value: 0 (LC 2) k-ft


Min Value: 0 (LC 2) k-ft



Selected Location Values:

Location: 0 ft
Max Value: 4.032 (LC 2) k
Min Value: 4.032 (LC 2) k


Member SJ4 Capacity, Envelope



Selected Location Values:

Location: 0 ft
Max Value: 0 (LC 2) k-ft
Min Value: 0 (LC 2) k-ft


Member SJ5 Capacity, Envelope



Selected Location Values:

Location: 0 ft
Max Value: 4.157 (LC 2) k
Min Value: 4.157 (LC 2) k


Member SJ5 Capacity, Envelope



Selected Location Values:

Location: 0 ft
Max Value: 0 (LC 2) k-ft
Min Value: 0 (LC 2) k-ft


Member SJ1 Demand, Envelope



Selected Location Values:

Location: 0 ft
Max Value: 3.484 (LC 2) k
Min Value: 3.484 (LC 2) k


Member SJ1 Demand, Envelope



Selected Location Values:

Location: 0 ft
Max Value: 0 (LC 2) k-ft
Min Value: 0 (LC 2) k-ft


Member SJ2 Demand, Envelope



Selected Location Values:

Location: 0 ft
Max Value: 3.645 (LC 2) k
Min Value: -3.329 (LC 2) k


Member SJ2 Demand, Envelope



Selected Location Values:

Location: 0 ft
Max Value: 0 (LC 2) k-ft
Min Value: 0 (LC 2) k-ft


Member SJ3 Demand, Envelope



Selected Location Values:

Location: 0 ft
Max Value: 3.731 (LC 2) k
Min Value: 3.731 (LC 2) k


Member SJ3 Demand, Envelope



Selected Location Values:

Location: 0 ft
Max Value: 0 (LC 2) k-ft
Min Value: 0 (LC 2) k-ft


Member SJ4 Demand, Envelope



Selected Location Values:

Location: 0 ft
Max Value: 3.816 (LC 2) k
Min Value: 3.816 (LC 2) k


Member SJ4 Demand, Envelope



Selected Location Values:

Location: 0 ft
Max Value: 0 (LC 2) k-ft
Min Value: 0 (LC 2) k-ft


Member SJ5 Demand, Envelope



Selected Location Values:

Location: 0 ft
Max Value: 3.966 (LC 2) k
Min Value: 3.966 (LC 2) k

Member SJ5 Demand, Envelope



Selected Location Values:

Location: 0 ft
Max Value: 0 (LC 2) k-ft
Min Value: 0 (LC 2) k-ft