



Campbell
STRUCTURAL


200 E. 16th St., Suite 100
Yuma, AZ 85364
(928) 726-2646

JOB SOMERTON LIBRARY 25073
SHEET NO. 1 OF 6
CALCULATED BY RLL DATE 9/2025
CHECKED BY _____ DATE _____
SCALE _____

Yuma County Somerton Library
HVAC Replacement
240 Canal Street
Somerton, AZ 85350

Client:

Sternco Engineers, Inc.
202 S. 1st Ave., Suite 205
Yuma, AZ 85364



Structural calculations for vertical support and seismic restraint at the new suspended fan coil units.

SEISMIC FORCES

$$\left. \begin{array}{l} S_{DS} = 0.53 \\ a_p = 2.5 \\ R_p = 2.5 \\ S_{b0} = 2.0 \end{array} \right\} \text{SUSPENDED VIBRATION ISOLATED}$$

$$F_p = \frac{0.4(2.5)(0.53)}{2.5} W_p(3)(1.0)$$

$$F_p = 0.64 \text{ klp} \leftarrow \text{GOVERNS}$$

$$F_{pmin} = 0.3(0.53)(1.0)W_p = 0.16 \text{ klp}$$

$$\text{MAX FAN COIL} = 250 \#$$

$$F_p = 0.64(250) = 160 \#$$

Site Soil Class: D - Default (see Section 11.4.3)

Results:

S_S :	0.609	S_{D1} :	N/A
S_1 :	0.261	T_L :	8
F_a :	1.313	PGA :	0.256
F_v :	N/A	PGA_M :	0.345
S_{MS} :	0.8	F_{PGA} :	1.344
S_{M1} :	N/A	I_e :	1
S_{DS} :	0.533	C_v :	1.105

Ground motion hazard analysis may be required. See ASCE/SEI 7-16 Section 11.4.8.

Data Accessed: Thu Sep 04 2025

Date Source: [USGS Seismic Design Maps](#)

UNISTRUT BETWEEN JOIST

$$P = 250 \left(\frac{1}{4} \right) (1.15) = 72 \text{ SAY } 80^{\#}$$

$$M = 80 (3.25) = 0.26^{\text{in-k}} = 3.12^{\text{in-k}}$$


UNISTRUT P1000

$$M_{\text{allow}} = 14.36^{\text{in-k}} = 1.20^{\text{in-k}}$$

$$DCR = \frac{3.12}{14.36} = 0.22 < 1.0 \text{ O.K.}$$


$$\Delta = \frac{Pa}{24EI} (3a^2 - 4a^2)$$

$$\Delta = \frac{0.08 (42) [3(108)^2 - 4(42)^2]}{24 (29 \times 10^3) (0.928)} = 0.15^{\text{in}} \frac{P}{1743} \text{ O.K.}$$



USE 2 UNISTRUT P1001 - TWO PER UNIT

CHANNEL SELECTION CHART

Channel	Channel Dimensions		Material & Thickness			Hole Pattern Styles						
												
	Width In (mm)	Height In (mm)	Steel gauge	Stainless Steel gauge	Alum. In (mm)	HS	T	WT	KO	SL	DS	H3
P1000	1½ (41.3)	1½ (41.3)	12 ga	12 ga	0.109 (2.8)	■	■	■	■	■	■	■
P1100	1½ (41.3)	1½ (41.3)	14 ga	14 ga	—	■	■	■	■	■	—	—
P2000	1½ (41.3)	1½ (41.3)	16 ga	—	—	■	■	■	■	■	—	—
P3000	1½ (41.3)	1½ (34.9)	12 ga	—	—	■	■	■	■	■	—	—
P3300	1½ (41.3)	¾ (22.2)	12 ga	12 ga	—	■	■	■	—	■	—	—
P4000	1½ (41.3)	1⅜ (20.6)	16 ga	16 ga	0.078 (2.0)	■	■	■	—	■	—	—
P4100	1½ (41.3)	1⅜ (20.6)	14 ga	—	—	■	■	■	—	■	—	—
P4400	1½ (41.3)	1 (25.4)	12 ga	—	—	■	■	■	—	■	—	—
P4520	1½ (41.3)	1⅜ (20.6)	12 ga	—	—	■	■	■	—	■	—	—
P5000	1½ (41.3)	3¼ (82.6)	12 ga	12 ga	—	■	■	■	■	■	—	—
P5500	1½ (41.3)	2⅞ (61.9)	12 ga	—	0.109 (2.8)	■	■	■	■	■	—	—

CHANNELS & COMBINATIONS IN DESCENDING ORDER OF STRENGTH

Channel	Area In ² (cm ²)	Weight lbs/ft (kg/m)	I In ⁴ (cm ⁴)	s In ³ (cm ³)	Allow. Moment In-lbs (N·m)
P5001	1.793	6.10	6.227	1.916	48,180
	11.57	9.1	259.2	31.4	5,440
P1004A	1.965	6.68	4.068	1.669	41,980
	12.68	9.9	169.3	27.4	4,740
P5501	1.452	4.94	2.805	1.151	28,940
	9.37	7.3	116.8	18.9	3,270
P1001C41	2.221	7.55	1.856	1.142	28,720
	14.33	11.2	77.2	18.7	3,250
P5000	0.897	3.05	1.098	0.627	15,770
	5.78	4.5	45.7	10.3	1,780
P1001	1.111	3.78	0.928	0.571	14,360
	7.16	5.6	38.6	9.4	1,620
P1101	0.835	2.84	0.733	0.451	11,340
	5.39	4.2	30.5	7.4	1,280
P3001	1.000	3.40	0.591	0.430	10,810
	6.45	5.1	24.6	7.0	1,220
P5500	0.726	2.47	0.522	0.390	9,820
	4.68	3.7	21.7	6.4	1,110
P2001	0.684	2.32	0.618	0.381	9,570
	4.41	3.5	25.7	6.2	1,080
P9200	0.489	2.23	0.279	0.297	7,480
	3.16	3.3	11.6	4.9	850
P4401	0.849	5.77	0.26	0.26	6,410
	5.48	8.5	10.6	4.2	725
A1001	0.609	2.07	0.302	0.242	6,070
	3.93	3.1	12.6	4.0	690
P9000	0.387	1.88	0.166	0.205	5,150
	2.50	2.8	6.9	3.4	580
P1000	0.555	1.89	0.185	0.202	5,070
	3.58	2.8	7.7	3.3	570
P3301	0.790	2.69	0.176	0.201	5,060
	5.10	4.0	7.3	3.3	570
P4521	0.77	2.62	0.15	0.18	4,538
	4.97	3.9	6.1	2.9	513

Channel	Area In ² (cm ²)	Weight lbs/ft (kg/m)	I In ⁴ (cm ⁴)	s In ³ (cm ³)	Allow. Moment In-lbs (N·m)
P1100	0.418	1.42	0.145	0.162	4,060
	2.69	2.1	6.0	2.6	460
P3000	0.500	1.70	0.120	0.153	3,850
	3.23	2.5	5.0	2.5	430
P4101	0.579	1.97	0.117	0.143	3,610
	3.74	2.9	4.9	2.4	410
P2000	0.342	1.16	0.125	0.140	3,520
	2.21	1.7	5.2	2.3	400
P4001	0.478	1.66	0.104	0.128	3,210
	3.14	2.5	4.3	2.1	360
A3301	0.459	1.56	0.077	0.103	2,590
	2.96	2.3	3.2	1.7	290
P4400	0.424	2.89	0.053	0.092	2,300
	2.74	4.3	2.2	1.5	260
A1000	0.305	1.04	0.061	0.086	2,170
	1.96	1.5	2.5	1.4	250
P3300	0.395	1.34	0.037	0.072	1,800
	2.55	2.0	1.5	1.2	200
P4520	0.384	1.31	0.031	0.064	1,615
	2.48	1.9	1.3	1.0	183
A4001	0.264	0.90	0.037	0.058	1,470
	1.70	1.3	1.5	1.0	170
P6001	0.213	0.73	0.045	0.055	1,400
	1.38	1.1	1.9	0.9	160
P4100	0.290	0.98	0.026	0.054	1,360
	1.87	1.5	1.1	0.9	150
P4000	0.244	0.83	0.023	0.049	1,230
	1.57	1.2	0.9	0.8	140
A3300	0.230	0.78	0.017	0.038	950
	1.48	1.2	0.7	0.6	110
P6000	0.107	0.36	0.009	0.020	510
	0.69	0.5	0.4	0.3	60
P7001	0.148	0.50	0.007	0.018	460
	0.96	0.8	0.3	0.3	50
P7000	0.074	0.25	0.002	0.007	170
	0.48	0.4	0.1	0.1	20

Combinations not shown in catalog are available on special order. Consult factory for more details.

SEISMIC BRACING CABLE


$$F_p = 160 \#$$

FORCE PER CABLE

$$T_D = 160 \left(\frac{1}{2} \right) (1.41) (1.41)$$

$$T_D = 160 \# / \text{CABLE}$$

$$T_{ASD} = 0.7 (160) = 112 \#$$



USE: 1/8" Φ 7X19 WIRE ROPE

$$T_{allow} = 400 \# \text{ WORKING LOAD}$$

$$DCR = \frac{112}{400} = 0.28$$