



Campbell STRUCTURAL

Robert L. Campbell Structural Engineer, P.C.
200 E. 16TH Street, Suite 100
Yuma, AZ 85364

JOB No.:

25032

DATE:

04/23/25

DESIGNED BY: RLC

CHECKED BY: RLC

SHEET 1

OF 33

CLIENT: Sternco Engineers, Inc.
202 S. 1st Ave, Suite 205
Yuma, AZ 85364

PROJECT: Yuma County Foothills Library
HVAC Replacement – Structural Report
13226 E. South Frontage Rd, Yuma AZ 85367



STRUCTURAL CALCULATIONS

DESIGN DATA

CODE DATA

CALCULATION SUMMARY

Building Code: 2018 I.B.C.

This project consists of replacing the existing roof top HVAC units at the Yuma Co. Foothills Library with new heavier units. The original construction documents show the steel roof joist are scheduled to support 1,500 lb mechanical units. The replacement units are in the range of 1,800 lb.

RCSE performed structural calculations to determine the existing joist shear and moment capacity. The same joists were checked with an actual dead load based on our field observations along with the 1,800 lb mechanical unit weight.

The results of our analysis indicate the existing steel joist capacity exceeds the new demand on the joist. All shear and moment demand/capacity ratio checks are less than 1.0 and consequently, no joist strengthening is required.

REVIEWED FOR CODE COMPLIANCE

Approved plans, specifications or inspection shall not be construed to approve a violation of any provision of an adopted code or ordinance of Yuma County


33 pages

By:

05/23/2025


12:44:03 PM

STAMPED APPROVED PLANS MUST BE ON SITE




STEEL JOIST ORIGINAL DESIGN CAPACITY


SJ1 DL+LLR LLR
 $w = 255 \text{ PLF} / 135 \text{ PLF}$
 $P = 1500 (\frac{1}{4}) = 375 \#$




SJ2
 $w = 255 \text{ PLF} / 135 \text{ PLF}$
 $P = 375 \#$




SJ3
 $w = 255 / 135 \text{ PLF}$
 $P = 375 \#$



SJ4
 $w = 255 / 135 \text{ PLF}$
 $P = 375 \#$




SJ5
 $w = 255 / 135 \text{ PLF}$
 $P = 375 \#$



NEW MECH UNITS
STEEL JOIST PROPOSED DESIGN DEMAND


S J 1 DL+LLR LLR
 $w = 233 \text{ PLF} / 135 \text{ PLF}$

$P = 1800 (1/4) = 450 \#$




S J 2

$w = 233 \text{ PLF} / 135 \text{ PLF}$
 $P = 450 \#$




S J 3

$w = 233 / 135 \text{ PLF}$
 $P = 450 \#$




S J 4

$w = 233 / 135 \text{ PLF}$
 $P = 450 \#$



S J 5

$w = 233 / 135 \text{ PLF}$
 $P = 450 \#$



EXISTING VS. NEW UNITS WEIGHTS

MARK	EXISTING UNIT INFORMATION			EXISTING UNIT WEIGHT W/ ACCESSORIES (LBS)	NEW UNIT WEIGHT W/ ACCESSORIES (LBS)				REMARKS
	MAKE	MODEL	SERIAL #		UNIT ONLY	PE ACCESSORY	CURB ADAPTER	TOTAL	
HP-1, 2	TRANE	WSC120A3R0A	820102570L (HP-1, TYP)	941 + 344 = 1285	1286	160	115	1561	1,2
HP-3,4,5,6,7	TRANE	WSC120A3R0A	820102588L (HP-3, TYP)	941 + 344 = 1285	1308	160	115	1581	1,2

REMARKS:

1. EXISTING UNITS INCLUDE CANFAB MODEL 6144-MPE ECONOMIZER AND POWERED EXHAUST ACCESSORIES.
2. ALL (7) UNITS SCHEDULED ARE THE SAME MODEL NUMBER AND A TYPICAL SERIAL NUMBER IS SHOWN.

NEW UNIT DESIGN WT
 $1581 + 215 = 1,800\#$

ORIGINAL DESIGN WT.
 curb
 $1285 + 215 = 1,500\#$

Robert L. Campbell
Structural Engineer, P.C.
 183 E. 24th Street, Suite 7
 Yuma, AZ. 85364

PROJECT
 Yuma County Library District
 Foothills Branch Library
 Yuma, AZ

Page 6 of 33 SHEET NO.:
 07040 3
 DATE: BY:
 Jun-07 KLB

GRAVITY DESIGN LOADS

2003 INTERNATIONAL BUILDING CODE - Dead and Live Loads

ROOF - High Roof Structure

DEAD LOADS

Corrugated Metal Roofing	2.0 psf
6" Polystyrene	3.0 psf
Steel Accoustic Deck	4.4 psf
Steel Beams	2.0 psf
MPE	2.0 psf
Sprinkler	1.5 psf
Misc.	1.1 psf
Total DL	16.0 psf

LIVE LOADS

Roof L_r **20 psf** (reducible)

BUILT UP ROOF - Main Structure

DEAD LOADS

Roofing	2.5 psf
6" Polystyrene	1.0 → 3.0 psf
Steel deck	2.3 psf
Steel Joists	2.0 psf
5/8 Gypboard Ceiling	ACOUS TIC CLG. 1.8 → 2.8 psf
MPE	1.8 psf
Sprinkler	1.5 psf
Misc.	2.1 psf
Total DL	18.0 psf

ACTUAL
 DL = 15 PSF

LIVE LOADS

Roof L_r **20 psf** (reducible)

CEILING - Vestibule Framing

DEAD LOADS

Light Gauge Framing	2.0 psf
Plywood	1.5 psf
5/8 Gypboard Ceiling	2.8 psf
MPE	1.8 psf
Sprinkler	1.9 psf
	10.0 psf

LIVE LOADS

Roof L_r (reducible)

Robert L. Campbell
Structural Engineer, P.C.

PROJECT

Foothills Branch Lib.

JOB NO.

07040

DATE

BY

SHEET NO.

Joist Design / Criteria

$$DL = 18 \text{ psf}$$

$$LLR = 20 \text{ psf}$$

$$W = 6.67(18 + 20) \text{ psf} = (120 + 133) \text{ plf}$$

Used: 16k (255/135) at 23'-2" span

ORIGINAL
CAPACITY →

20k (255/135) at 28'-1" span

24k (255/135) at 33'-4" span

26k (255/135) at 40'-2" span

ACTUAL UNIFORM

$$\begin{matrix} (233/135) \\ \uparrow & \uparrow \\ TL & LLR \end{matrix}$$



INNOVATIONS FOR LIVING®

FOAMULAR® Extruded Polystyrene (XPS) Insulation

SI and I-P Units for Selected Properties

Technical Bulletin

This bulletin provides thermal conductivity, thermal resistance, density and compressive strength for FOAMULAR® 150, 250, 400, 600 and 1000 insulation in thicknesses of 2", 3" and 4". SI units are provided in the tables, followed by I-P units in parenthesis.

FOAMULAR® 150 Insulation

Thickness, mm	Thermal Conductivity, W/mK, max.	Thermal Resistance, m ² K/W, min.	Density, kg/m ³ , min.	Compressive Strength, kPa, min.
100 (4")	0.029 (k=0.20)	3.53 (R-20)	20.8 (1.3 pcf)	103 (15 psi)
75 (3")	0.029 (k=0.20)	2.65 (R-15)	20.8 (1.3 pcf)	103 (15 psi)
50 (2")	0.029 (k=0.20)	1.77 (R-10)	20.8 (1.3 pcf)	103 (15 psi)

FOAMULAR® 250 Insulation

Thickness, mm	Thermal Conductivity, W/mK, max.	Thermal Resistance, m ² K/W, min.	Density, kg/m ³ , min.	Compressive Strength, kPa, min.
100 (4")	0.029 (k=0.20)	3.53 (R-20)	24.8 (1.55 pcf)	172 (25 psi)
75 (3")	0.029 (k=0.20)	2.65 (R-15)	24.8 (1.55 pcf)	172 (25 psi)
50 (2")	0.029 (k=0.20)	1.77 (R-10)	24.8 (1.55 pcf)	172 (25 psi)

FOAMULAR® 400 Insulation

Thickness, mm	Thermal Conductivity, W/mK, max.	Thermal Resistance, m ² K/W, min.	Density, kg/m ³ , min.	Compressive Strength, kPa, min.
100 (4")	0.029 (k=0.20)	3.53 (R-20)	28.9 (1.8 pcf)	276 (40 psi)
75 (3")	0.029 (k=0.20)	2.65 (R-15)	28.9 (1.8 pcf)	276 (40 psi)
50 (2")	0.029 (k=0.20)	1.77 (R-10)	28.9 (1.8 pcf)	276 (40 psi)

FOAMULAR® 600 Insulation

Thickness, mm	Thermal Conductivity, W/mK, max.	Thermal Resistance, m ² K/W, min.	Density, kg/m ³ , min.	Compressive Strength, kPa, min.
100 (4")	0.029 (k=0.20)	3.53 (R-20)	35.3 (2.2 pcf)	414 (60 psi)
75 (3")	0.029 (k=0.20)	2.65 (R-15)	35.3 (2.2 pcf)	414 (60 psi)
50 (2")	0.029 (k=0.20)	1.77 (R-10)	35.3 (2.2 pcf)	414 (60 psi)

FOAMULAR® 1000 Insulation

Thickness, mm	Thermal Conductivity, W/mK, max.	Thermal Resistance, m ² K/W, min.	Density, kg/m ³ , min.	Compressive Strength, kPa, min.
100 (4")	0.029 (k=0.20)	3.53 (R-20)	48.1 (3.0 pcf)	690 (100 psi)
75 (3")	0.029 (k=0.20)	2.65 (R-15)	48.1 (3.0 pcf)	690 (100 psi)
50 (2")	0.029 (k=0.20)	1.77 (R-10)	48.1 (3.0 pcf)	690 (100 psi)

Notes:

- SI, the International System of Units (Metric), I-P, inch-pound units (English).
- Conversions are approximate, rounded to the nearest significant digit that is customary for a given property as shown in the tables.
- I-P unit definitions:
 Thermal Conductivity, "k" = Btu·in/ft.²·hr·°F
 Thermal Resistance, "R" = hr·ft²·°F/Btu
 Compressive Strength, "psi" = pounds per square inch
 Density, "pcf" = pounds per cubic foot

$$\frac{3}{12} \times 4 = 1.0 \text{ PSF}$$

Disclaimer of Liability

Technical information contained herein is furnished without charge or obligation and is given and accepted at recipient's sole risk. Because conditions of use may vary and are beyond our control, Owens Corning makes no representation about, and is not responsible or liable for the accuracy or reliability of data associated with particular uses of any product described herein. Nothing contained in this bulletin shall be considered a recommendation.




INNOVATIONS FOR LIVING®

OWENS CORNING FOAM INSULATION, LLC
 ONE OWENS CORNING PARKWAY
 TOLEDO, OHIO 43659

1-800-GET-PINK®
www.owenscorning.com

Pub. No. 10015703. Printed in U.S.A. September 2011. THE PINK PANTHER™ & ©1964-2011 Metro-Goldwyn-Mayer Studios Inc. All Rights Reserved. The color PINK is a registered trademark of Owens Corning. ©2011 Owens Corning.




DEMAND/CAPACITY TABLE


REF: RISA 3d Printout

	CAPACITY		CF	DEMAND		DCR	
	V (K)	M (L-K)		V (K)	M (L-K)	V	M
SJ1	4.135	27.6	3.94	26.05	0.95	0.94	
SJ2	3.889	25.78	3.645	23.78	0.94	0.92	
SJ3	3.961	29.46	3.73	28.2	0.94	0.96	
SJ4	4.03	29.18	3.82	27.92	0.95	0.96	
SJ5	4.157	27.3	3.97	25.65	0.96	0.94	

DEMAND ON JOIST IS LESS THAN CAPACITY
THEREFORE JOIST ARE O.K.



	RCSE	Steel Joist Capacity Check	SK-1
	Rob		Steel Joist Check.r3d
	25032		




Loads: BLC 1, Dead



RCSE
Rob
25032

Steel Joist Capacity Check

SK-2
Steel Joist Check.r3d



Loads: BLC 2, Roof Live




RCSE
Rob
25032

Steel Joist Capacity Check

SK-3

Steel Joist Check.r3d



Loads: LC 2, DL+RLL

IRISA
ANALYSIS SOFTWARE COMPANY


RCSE
Rob
25032

Steel Joist Capacity Check

SK-4


Steel Joist Check.r3d

Member S.J1 Capacity, Envelope



Selected Location Values:
 Location: 0 ft
 Max Value: 3.755 (LC 2) k
 Min Value: 3.755 (LC 2) k


Member SJ1 Capacity, Envelope



Selected Location Values:


Location: 0 ft
Max Value: 0 (LC 2) k-ft
Min Value: 0 (LC 2) k-ft

Member SJ2 Capacity, Envelope



Selected Location Values:
Location: 0 ft
Max Value: 3.889 (LC 2) k
Min Value: 3.889 (LC 2) k

Member SJ2 Capacity, Envelope




Selected Location Values:

Location: 0 ft

Max Value: 0 (LC 2) k-ft

Min Value: 0 (LC 2) k-ft


Member SJ3 Capacity, Envelope



Selected Location Values:


Location: 0 ft
 Max Value: 3.961 (LC 2) k
 Min Value: 3.961 (LC 2) k

Member SJ3 Capacity, Envelope



Selected Location Values:
Location: 0 ft
Max Value: 0 (LC 2) k-ft
Min Value: 0 (LC 2) k-ft


Member SJ4 Capacity, Envelope



Selected Location Values:

Location: 0 ft
 Max Value: 4.032 (LC 2) k
 Min Value: 4.032 (LC 2) k

Member SJ4 Capacity, Envelope




Selected Location Values:

Location: 0 ft

Max Value: 0 (LC 2) k-ft

Min Value: 0 (LC 2) k-ft


Member SJ5 Capacity, Envelope



Selected Location Values:


Location: 0 ft
 Max Value: 4.157 (LC 2) k
 Min Value: 4.157 (LC 2) k

Member SJ5 Capacity, Envelope




Selected Location Values:
Location: 0 ft
Max Value: 0 (LC 2) k-ft
Min Value: 0 (LC 2) k-ft

Member SJ1 Demand, Envelope




Selected Location Values:
 Location: 0 ft
 Max Value: 3.484 (LC 2) k
 Min Value: 3.484 (LC 2) k

Member SJ1 Demand, Envelope



Selected Location Values:
Location: 0 ft
Max Value: 0 (LC 2) k-ft
Min Value: 0 (LC 2) k-ft


Member SJ2 Demand, Envelope



Selected Location Values:


Location: 0 ft
Max Value: 3.645 (LC 2) k
Min Value: 3.645 (LC 2) k

Member SJ2 Demand, Envelope




Selected Location Values:
Location: 0 ft
Max Value: 0 (LC 2) k-ft
Min Value: 0 (LC 2) k-ft

Member SJ3 Demand, Envelope



Selected Location Values:
 Location: 0 ft
 Max Value: 3.731 (LC 2) k
 Min Value: 3.731 (LC 2) k

Member SJ3 Demand, Envelope




Selected Location Values:

Location: 0 ft

Max Value: 0 (LC 2) k-ft

Min Value: 0 (LC 2) k-ft


Member SJ4 Demand, Envelope



Selected Location Values:

Location: 0 ft
 Max Value: 3.816 (LC 2) k
 Min Value: 3.816 (LC 2) k


Member SJ4 Demand, Envelope



Selected Location Values:


Location: 0 ft
Max Value: 0 (LC 2) k-ft
Min Value: 0 (LC 2) k-ft

Member SJ5 Demand, Envelope



Selected Location Values:
 Location: 0 ft
 Max Value: 3.966 (LC 2) k
 Min Value: 3.966 (LC 2) k

Member SJ5 Demand, Envelope



Selected Location Values:

Location: 0 ft
 Max Value: 0 (LC 2) k-ft
 Min Value: 0 (LC 2) k-ft